


Protector Digital Standalone Manual

Table of Contents

SPECIFICATIONS.....	2
Values measured.....	2
Functions.....	2
Communication ports and protocols.....	2
SETTING AN IP ADDRESS.....	4
BACNET/IP.....	4
MODBUS.....	5
RTU.....	5
TCP.....	5
Holding Registers.....	5
SUPPORTED SENSORS.....	6
CONNECTION DIAGRAMS.....	7
Overview.....	7
SENSORS.....	8
Sensorex s272 pH/ORP.....	8
Sensorex Lumin-S Dissolved Oxygen.....	8
Hamilton VisiFerm RS485 Dissolved Oxygen.....	8
Mettler Toledo pH/DO with M200 transmitter.....	8
ON-SCREEN DATA AND CONTROLS.....	9
Setup Wizard.....	9
Main screen.....	9
Tools menu.....	10
Network settings.....	11
Flowmeter settings.....	12
Pressure control.....	13
Back flushing.....	14
DRAWING.....	15
CONTACTS.....	16



SPECIFICATIONS

Values measured

#	Value	Range
1	Water flow	3..100 l/min
2	Flow counter	0..9999 m3
3	Water temperature	0..110 °C
4	Electro conductivity (EC)	0..2000 µS/cm
5	Anode current	0..200 mA
6	Pressure	0..10 bar
7	Pressure difference	0..100kPa
8	PH, optional	0..14
9	Dissolved oxygen (DO), optional	0..20 mg/l
10	Fill water amount, optional, requires Digital Filling Unit (DFU)	0..9999m3
11	Fill water electro conductivity (EC), optional, requires DFU.	0..2000 µS/cm

Functions

1	Automatic drain (sludge back flush). Requires drain/inlet valves.
2	Automatic pressure control. Requires fill valve.


Communication ports and protocols

Port	Protocol	Usage
RS485 1	MODBUS RTU/Master	1. MODBUS/RTU sensors (pH, DO, ORP) 2. Digital Filling Unit
RS485 2	MODBUS/RTU Slave	Connect to a building control system
4..20mA input	-	1. 4..20mA pH/DO/ORP sensors 2. Pressure sensors
4..20mA out	-	Connect to a building control system
Ethernet RJ-45	MODBUS/TCP	Connect to a building control system
	BACNet/IP	Connect to a building control system
	HTTPS (out)	Send data to IWT CRM.
	HTTP (in) on local port 80	Local web-server. View data on the Protector built-in web page.
	MQTTs to port 8883	IoT protocol for sending realtime data.

Details

1. **Modbus-RTU master (over RS485).** Used to communicate with RS485 sensors and Digital Filling Unit.

2. **BACNet/IP.** Used to connect Protector to a Building Control System (BCS).
3. **Modbus-RTU slave (over RS485).** Connect Protector to different gateways or building control systems using RS485 interface. Instant values from all sensors are provided by Modbus-RTU.
4. **Modbus-TCP.** The most convenient way to connect Protector to a building control system. Many systems support Modbus-TCP, and Protector allows getting instant values from all the sensors by this protocol.
5. **Sending data to IWT CRM by https.** By default if Protector is connected to the Internet, it sends all data to IWT CRM (<https://crm.iwtm.com>), where customers can view and analyze it.



6. **Built-in web-server.** Using the IP address on screen, you can connect to Protector using any Internet browser. You will see a web-page showing all instant and historic data in charts, same as in the CRM. Protector firmware can be upgraded from this page.

PROTECTOR DIGITAL

- HOME
- SYSTEM
- UPGRADE
- NETWORK
- DATA RESET
- FACTORY RESET
- PASSWORD
- LOGOUT

System State

Serial number: 02-2112-00034
Firmware version: v1.2.16_2023-05-11_707016f5
Time: 30.05.23 14:24:27 UTC
Uptime: 0d 23:05:11
CPU Load: 59%
CPU temperature: 50.15°C
FreeRTOS Heap: 32864 B
NVRAM Battery: 99%

SOFTWARE_RESET (Hardware reset)

Task list:
(click header to sort)

ID	Task name	Priority	Stack	Free	Used	
1	MB Slave TCP	R	8000	8	97	28
2	MB Slave RS	R	12800	26	86	19
3	MB Master RS	R	2048	29	87	10
4	TouchGFX	B	2048	14	82	0
5	SSL Client	B	1024	17	80	0
6	Sensors	B	3000	4	77	0
7	Modbus Master	B	4800	8	90	0
8	Supervisor	B	1024	19	85	0
9	Network	B	3600	13	84	0
10	TCP/IP Stack	B	16384	3	76	0
11	Eth Input	B				
12	Eth Link	B				
13	VNC Server	B				

PROTECTOR DIGITAL

Firmware Upgrade

Current version: v1.2.16_2023-05-11_707016f5

Please specify a binary file to upload into STM32F4x7 flash:

no file selected

SETTING AN IP ADDRESS

See Network settings on page 11.

BACNET/IP

Hardware connection: RJ-45 Cat 5E 100Mb

Default object id: 102. Can be changed by BACNet.

Analog Input Objects:

Name	Units	Range
Anode current	mA	0..200
Flow counter	m ³	0..9999999
Flow	l/min	0..50
Conductivity	µS/cm	0..2000
Temperature	°C	0..110
Inlet pressure	kPa	0..1000
Outlet pressure	kPa	0..1000
pH	-	0..14
Dissolved oxygen	mg/l	0..20
ORP redox	-	-2000..2000
Pressure difference	kPa	0..100

Binary Output Objects

Name	Function
Drain	Open drain valve. The valve will close automatically after max drain duration time.
Fill	Open fill valve. The valve will close automatically when reached max pressure or after 30 seconds.

MODBUS

RTU

Hardware connection: terminals 21-23:

21	SG	MB SL
22	B	
23	A	

Setting slave address and speed:

(See fig. 1)

1. Go to Tools → Settings → Connections
2. Set speed and address
3. Tap “Save”.

Parity and stop bits are always 8N1 (8 bits, no parity, 1 stop bit).

TCP

Hardware connection: RJ-45 Cat 5E 100Mb

Address: 1

Holding Registers

reg #	RW	Type	RTU	TCP	Value	Units	Range
0	RW	UINT16	✓	✗	MB Address		
1	RW	UINT16	✓	✗	MB Speed, baud		
2	RO	UINT32	✓	✓	Timestamp	seconds	
4	RO	float dcba	✓	✓	Anode current (0..200mA)	mA	0..200
6	RO	float dcba	✓	✓	Flow counter, m3	m3	0..9999999
8	RO	float dcba	✓	✓	Flow, liters/min, (0..50 l/min)	l/min	0..50
10	RO	float dcba	✓	✓	Conductivity (0..2000 uS/cm)	µS/cm	0..2000
12	RO	float dcba	✓	✓	Temperature (0..110 °C)	°C	0..110
14	RO	float dcba	✓	✓	Inlet pressure, kPa (0..1000 kPa)	kPa	0..1000
16	RO	float dcba	✓	✓	Outlet pressure, kPa (0..1000 kPa)	kPa	0..1000
18	RO	float dcba	✓	✓	pH, (0..14), optional	-	0..14
20	RO	float dcba	✓	✓	Dissolved oxygen, mg/l, optional	mg/l	0..20
22	RO	float dcba	✓	✓	ORP redox	-	-2000..2000




Figure 1: MODBUS settings

28	RO	float dcba	✓	✓	Pressure difference	%	0..100
30	RO	float dcba	✓	✓	DFU flow counter	m3	0..9999
32	RO	float dcba	✓	✓	DFU flow	l/min	0..100
34	RO	float dcba	✓	✓	DFU Conductivity	µS/cm	0..2000
36	RO	float dcba	✓	✓	DFU Temperature	°C	0..60
38	RO	float dcba	✓	✓	DFU Pressure	kPa	0..1000

SUPPORTED SENSORS


#	Value	Manufacturer	Output	Model	Comment
1	EC/T/Flow	IWTM	Raw	FS-8800	7 wires connected directly to terminals
1	Pressure	Any	4..20mA	Any	Range 0..1000kPa
2	pH	Mettler Toledo	4..20mA	InPro3250i	Requires M100 or M200 transmitter from Mettler Toledo in a separate box.
3	DO	Mettler Toledo	4..20mA	InPro6850i	
4	pH	Sensorex	RS485	S272	
5	ORP	Sensorex	RS485	S272	
6	DO	Sensorex	RS485	LUMIN-S	
7	DO	Hamilton	RS485	VisiFerm RS485 Arc	
8	Flow	Any	Pulse	Any	Supports hall-effect (3-wire with 5V power) and mechanical (2-wire) turbine flow meters.
9	Anode current	n/a	current	n/a	Direct connection to terminals. Max current is 200mA.

IMPORTANT NOTES:

1. Never connect sensors with the device powered on.
2. MODBUS/RTU (RS485) sensors are detected on boot within 15 seconds. If not detected, please turn Protector off, check connections and turn on.


CONNECTION DIAGRAMS

Overview




SENSORS


Sensorex s272 pH/ORP




Hamilton VisiFerm RS485 Dissolved Oxygen



Sensorex Lumin-S Dissolved Oxygen



Mettler Toledo pH/DO with M200 transmitter




ON-SCREEN DATA AND CONTROLS

Setup Wizard

On a first start Protector will run a Setup Wizard which guides through all settings required.


Main screen



1. **Charts.** Tap and drag to scroll the graphs.
2. **Scale buttons.** “HOURS” shows 1 point per 10 minutes. “DAYS”–1 point per day.
3. **Tools button.** Opens tools menu.
4. **Valve indicators** show when FILL, INLET and DRAIN valves are active.

Tools menu

Tap “Tools” button.



1. **Anodes switch.** Manually switch off the anodes.
2. **Manual back flushing.** Tap and hold to drain the system manually.
3. **Full drain.** Tap this button to empty the tank and put the system into maintenance mode before doing service to the Protector.
4. **Refill.** Tap this to refill the system after maintenance and return to normal mode.
5. **Settings.** Open settings menu. A PIN-code required.

Network settings

Tools → Settings → PIN-code → NETWORK.

The screenshot shows the 'Network settings' interface. At the top, the title 'Network settings' is displayed in blue. Below it, the 'DHCP client' toggle is set to 'OFF'. The 'IP address' field contains '192.168.1.179', 'Network mask' contains '255.255.255.0', 'Gateway' contains '192.168.1.3', and 'DNS' contains '192.168.1.3'. The 'Link:' status is 'connected' in green, and 'DB' is also in green. Below these, the current IP parameters are listed: 'IP 192.168.1.179', 'NM 255.255.255.0', 'GW 192.168.1.3', and 'DNS 192.168.1.3'. At the bottom, there is a numeric keypad with buttons for digits 0-9, 'X', and a decimal point, along with 'BACK' and 'SAVE' buttons. Three callout boxes are present: one pointing to the IP address field labeled 'Static IP parameters', one pointing to the 'Link:' and 'DB' status labeled 'Link and Database connection status', and one pointing to the current IP parameters section labeled 'Current IP parameters'.

Network settings

DHCP client ☐ OFF ☐ ON

IP address 192.168.1.179

Network mask 255.255.255.0

Gateway 192.168.1.3

DNS 192.168.1.3

Link: connected DB

IP 192.168.1.179 NM 255.255.255.0

GW 192.168.1.3 DNS 192.168.1.3

7 8 9

4 5 6

1 2 3

X 0 .

BACK SAVE

Static IP parameters

Link and Database connection status

Current IP parameters

1. **Dynamic IP-address.** Enable DHCP client to obtain IP-address automatically.
2. **Static IP-address.**
 1. Disable DHCP client.
 2. Enter static IP, network mask, gateway and DNS. If you have no DNS address, enter 8.8.8.8 or 1.1.1.1.
 3. Tap "Save".

Flowmeter settings

Tools → Settings → PIN-code → FLOWMETER & EC.

The screenshot shows a 'Flowmeter settings' screen with a dark background. At the top, the title 'Flowmeter settings' is in light blue. Below it, 'Flow constant (imp/l)' is followed by a text input field containing the number '27'. A callout bubble points to this field with the text 'Flow constant'. Underneath, 'Common values:' is followed by three buttons: '1" - 71', '1,5" - 27', and '2" - 12'. A callout bubble points to these buttons with the text 'Flow constant presets'. Below this section is the 'EC sensor settings' section. It has two options: '1" Combined EC and flow' with an unchecked checkbox, and 'Other EC probe' with a checked checkbox. At the bottom, there are two buttons: 'BACK' and 'SAVE'.

1. **Flow constant.** Select one of the presets or enter the constant manually. Flow constant is number of pulses per litre.
2. **EC sensor settings.** Select '1" combined EC and flow' for the FS-8800 combined sensor. If you have any other conductivity sensor, select "Other EC probe".

Pressure control

Tools → Settings → PIN-code → PRESSURE CONTROL.

PRESSURE CONTROL

Auto pressure control ☐ OFF ☒ ON

Security valve, bar

Normal pressure range

Max, bar

Min, bar

Abs min pressure, bar

7 8 9

4 5 6

1 2 3

X 0 .

BACK SAVE

1. **Auto pressure control.** When turned on, Protector will keep the pressure between Min and Max values by refilling system. Fill valve needs to be connected for pressure control.
2. **Security valve.** Enter your system security valve pressure.
3. **Max.** Maximum pressure in the system. Protector will fill up to this level.
4. **Min.** Minimum pressure in the system. When below, Protector will start refilling.
5. **Abs min pressure.** Absolute minimum pressure. Protector will never drain the system below this pressure level.

Back flushing

Tools → Settings → PIN-code → BACK FLUSHING.

BACK FLUSHING

Auto back flushing OFF ON

Difference to drain, % - 10 +

Drain interval, days - 1 +

Max drain duration, s - 17 +

Pressure difference calibration

Inlet, bar 2.815

Outlet, bar 2.837

Difference (comp), kPa 0.2


Calibration requires no flow through the Protector.
If you don't have an automatic inlet valve, please
stop the flow manually. Press "CALIBRATE" when
ready. Difference should be nearly zero when
properly calibrated.

CALIBRATE

BACK SAVE

1. **Automatic back flushing.** If enabled, Protector will from time to time drain the system according to the settings. Drain valve needs to be installed in the system.
2. **Difference to drain.** Pressure difference higher than this setting indicates that the filter is slugged and needs to be drained immediately.
3. **Drain interval in days.** The system will be drained after this number of days regardless of the pressure difference.
4. **Max drain duration.** Number of seconds the drain valve will stay open.
5. **Pressure difference calibration.** In order to detect pressure difference and slugged state of the tank Protector need the pressure sensors to be calibrated. Follow instructions on the screen to calibrate.

DRAWING



CONTACTS

International Water Treatment Maritime AS,

Bjerkås næringspark bygg 21, PB 54

3470 Slemmestad

NORWAY

Phone: +4731287171

Email: info@iwtm.com